

EX Instructions

Number of EC type examination certificate

TÜV 00 ATEX 1557 X

Amendment to operating instructions for these type series

Type	Description	Instructions
CB/CE/CC6xx1	Pressure transmitter COMPACT	BA_005
CX6001	High-temperature pressure transmitter	BA_076

Marking

II 2 G Ex ib IIC T6 Gb

- BG: Ако не разбираете указанията за безопасност, можете да изискате превод на вашия език.
CZ: Pokud těmto bezpečnostním pokynům nerozumíte, můžete si vyžádat jejich překlad do vašeho jazyka.
DA: Hvis du ikke forstår sikkerhedshenvisningerne, kan du forespørge en oversættelse i dit sprog.
DE: Wenn Sie diese Sicherheitshinweise nicht verstehen, können Sie eine Übersetzung in Ihrer Landessprache anfordern.
EL: Εάν δεν καταλαβαίνετε αυτές τις υποδείξεις ασφαλείας, μπορείτε να ζητήσετε μια μετάφραση στη μητρική σας γλώσσα.
ES: Si no entiende estas indicaciones de seguridad, puede solicitar una traducción en su idioma.
ET: Kui need ohutusnõuded ei ole teile arusaadavad, võite tellida meilt tõlke oma keelde.
FI: Jos et ymmärrä näitä turvaohjeita, voi pyytää ne lähettääväksi omalle kielelllesi käännettynä.
FR: Si vous ne comprenez pas les consignes de sécurité, vous pouvez faire la demande d'une traduction dans votre langue.
HU: Amennyiben nem érti ezeket a biztonsági utasításokat, akkor kérheti ezeknek az Ön nyelvére lefordított változatát.
IT: Nel caso non capite queste avvertenze di sicurezza, ne potete richiedere una traduzione nella vs. lingua.
LT: Jei nesuprantate šiu saugos reikalavimų, galite užsisakyti jų vertimą į Jūsų kalbą.
LV: Ja jūs nesaprotat šos drošības norādījumus, jūs varat pieprasīt tulkojumu jūsu valodā.
NL: Indien u deze veiligheidsinstructies niet begrijpt, kunt u een vertaling in uw eigen taal aanvragen.
PL: Jeżeli niniejsze przepisy bezpieczeństwa są niezrozumiałe, można poprosić o tłumaczenie we własnym języku.
PT: Se não compreender os avisos de segurança, pode solicitar uma tradução no seu idioma.
RO: Dacă nu înțelegeți aceste instrucțiuni de siguranță puteți cere traducerea acestora în limba dvs.
SK: Ak ste nepochopili bezpečnostné pokyny, môžete si vyžiadať preklad do svojho jazyka.
SL: Če teh navodil ne razumete, lahko zahtevate prevod v Vaš jezik.
SV: Om du inte förstår den här säkerhetsanvisningen kan du begära att få en översättning till ditt språk.

1 General Safety Notes

The installation, set up, service or disassembly of this device must only be done by trained, qualified personnel using suitable equipment and authorized to do so.



Warning

Media can escape if unsuitable devices are used or if the installation is not correct.

Danger of severe injury or damage

- Ensure that the device is suitable for the process and undamaged.

Measuring devices in explosive environments must be installed and commissioned by competent personnel that are familiar with the specialties of explosion protection. Modifications or damage of devices or electrical connections might negatively influence the operating safety or the ex-proofing.

Observe the regulations and standards for erection and operation of electrical installations in explosive atmospheres as well as the installation and safety notes in the corresponding operation instructions.

Avoid electrostatic charge on plastic surfaces, if present.

2 Requirements for intrinsically safe supply

Connect the pressure transmitter to a certified intrinsically safe power circuit.

Permissible maximum values:

$$U_i \leq 30 \text{ V}$$

$$I_i \leq 150 \text{ mA}$$

$$P_i \leq 1000 \text{ mW}$$

Effective internal inductance:

$$L_i \leq 33 \mu\text{H}$$

Effective internal capacity:

$$C_i \leq 49 \text{ nF}$$

Since the intrinsically safe signal circuit is connected with earth potential for safety reasons, potential equalisation has to exist in the complete course of the erection of the intrinsically safe circuit.

At a cable length above 50 m the intrinsically safe circuit has to be safe galvanically separated from all non-intrinsically safe circuits.

The connection cable is not part of the EC type examination certificate and must be considered separately per EN 60079-14:2014 section 16.2.2.2. According to that standard you can assume the following values:

$$C_c \leq 200 \text{ pF/m}$$

$$L_c \leq 1 \mu\text{H/m}$$

3 Permissible ambient temperatures

<u>Type</u>	<u>Marking</u>	<u>Class</u>	<u>Ambient</u>
All	II 2 G Ex ib IIC T6 Gb	T6	-40...70 °C

For temperature classes T1 to T5 the temperature limits for T6 apply.

The permissible media and ambient temperatures depend on the device type and its configuration as documented in the data sheet as well as the ignition temperature of the explosive atmosphere. Consider both aspects! The permissible range lies between the lowest value of the upper limit and the highest value of the lower limit.



Lösungen nach Maß für industrielle Druck- und Temperaturmessungen in den Bereichen Food, Pharma, Biotechnik, Chemie, Petrochemie, Energie, Umweltschutz und Seeschifffahrt.
"Made to Measure" Process Instrumentation for Pressure and Temperature Measurement in the Food, Pharmaceutical, Bio-Technology, Chemical, Petro-Chemical, Power, Environmental and Maritime Industries.

EU-Konformitätserklärung *EU Declaration of Conformity*

KE_022

Hersteller / Manufacturer

LABOM Mess- und Regeltechnik GmbH
Im Gewerbepark 13, 27798 Hude

Die CE-Kennzeichnung der Geräte

The CE symbol on the devices

Druckmessumformer **COMPACT** der Typenreihen **Pressure transmitter COMPACT**, type series

Cx6xxx

weist auf die Übereinstimmung mit den relevanten
Richtlinien hin.

*indicates their compliance with the relevant
directives.*

Folgende Richtlinien werden angewandt:

The following directives are applied:

2014/68/EU	DGRL PED	PS > 200 bar: Modul H druckhaltendes Ausrüstungsteil PS > 200 bar: Module H pressure accessory	
2011/65/EU	RoHS	EN 50581:2012	
2014/30/EU	EMV EMC	EN 61326-1:2013	
2014/34/EU	ATEX	EN 60079-0:2012/A11:2013 EN 60079-11:2012	Für Typenreihe / <i>For type series Cx6xx1</i> Nr. der EG-Baumusterprüfungsbereinigung <i>EC-type examination certificate</i>

TÜV 00 ATEX 1557 X

Ausgestellt von / *issued by*
0044 TÜV NORD CERT

Hude, 28.12.2017

pp. Dr. Thomas Köster
Leiter Bereich Entwicklung / R & D Director

benannte Stellen für Auditierung des QS-Systems nach
notified bodies for auditing the QS-system according to

ATEX
Zertifikat / *certificate*

0044 TÜV NORD CERT
TÜV 00 ATEX 1582 Q

DGRL / *PED*
Zertifikat / *certificate*

0045 TÜV NORD Systems
07 202 1321 Z 0042/12/02